

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE <div style="text-align: center;">J</div>		PAGE OF PAGES <div style="text-align: center;">1   3</div>	
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">0002</div>		3. EFFECTIVE DATE <div style="text-align: center;">20-Jun-2005</div>		4. REQUISITION/PURCHASE REQ. NO. SEE SCHEDULE		5. PROJECT NO.(If applicable)	
6. ISSUED BY U.S. ARMY CORPS OF ENGINEERS, CHARLESTON ATTN: CONTRACTING DIVISION 69-A HAGOOD AVENUE CHARLESTON SC 29403-5107		CODE W912HP		7. ADMINISTERED BY (If other than item 6) <div style="text-align: center; font-weight: bold;">See Item 6</div>			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X 9A. AMENDMENT OF SOLICITATION NO. W912HP-05-R-0008			
				X 9B. DATED (SEE ITEM 11) 20-May-2005			
				10A. MOD. OF CONTRACT/ORDER NO.			
				10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to answer questions and to establish a new date for receipt of proposals. See Summary of Changes.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  20-Jun-2005	

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

## SECTION 00010 - SOLICITATION CONTRACT FORM

The required response date/time has changed from 20-Jun-2005 02:00 PM to 30-Jun-2005 02:00 PM.

(End of Summary of Changes)

**The following items are applicable to this modification:**QUESTIONS & ANSWERS

The following questions have been submitted and responses are provided:

1. The structural drawings for the office building indicate some masonry walls in the interior of the office, the architectural drawings indicate gypsum walls. Which is correct?

Answer: The walls should be gypsum wallboard as shown on the Architectural Drawings.

2. In reference to specification section 1451A, are we interpreting the requirement of the section correctly that a CQC Manager, a CQC Civil Engineer, a submittals clerk, and a concrete, soils and pavement technician are required on this project?

Answer: Reference paragraph 3.4.1 of Section 01451A: A CQC Systems Manager is required. This individual is to be assigned no other duties. Other personnel are required in the civil, materials, and submittals clerk area. These functions may be provided by one or more individuals as required (not necessarily dedicated individuals) and these individuals may be assigned other duties. Personnel providing these functions must meet the qualifications stated in the Experience matrix.

3. Can a subcontracted testing lab be used in lieu of the requirement in specification section 1451A paragraph 3.4.3 for the concrete, soils, pavement technician?

Answer: A concrete, pavement, and soils technician is required to be on site anytime this work is ongoing. This technician may be provided by a materials testing lab provided the above requirements are satisfied and the materials lab is under direct sub-contract to the construction contractor.

4. Is the existing project labor agreement with the site applicable to this contract?

Answer: This is a Corps of Engineers Contract. The site project labor agreement does not apply.

5. Is colored mortar required for the integrally colored CMU?

Answer: Mortar is to match the CMU.

6. Reference Drawing A12: Is insulation required between the metal decking and the Standing Seam Roof? The drawings indicate felt paper.

Answer: Composite insulation board is required between metal decking and standing seam metal roof.

7. Drawing A-6 on Detail B calls a fixed window; however the window schedule calls for a hollow metal window single glazed unit. Which is correct?

Answer: The hollow metal window single glazed unit.

8. The large combo unit pet door will not work in 8" wall.

Answer: Pet door should be Carlson Products or approved equal for a 16"W X 24"H finished opening. The type "A" frame (DW-Kennel-19) should be used; however, contractor will be required to provide shop drawings of proposed door assembly after contract award. Use the Type A frame part no.

9. Can Zurn Z-886 Trench Drain be used in lieu of the trench drain specified.

Answer: On the drawings, the trench drain is specified on an "or approved equal basis". "Equal" will be determined after contract award as a part of the shop drawing review process.

10. Concerning the doors 4-15 on the door schedule on drawing "A8" and the Division 8 specs: The above mentioned doors are referenced as hollow metal doors and division 8 of the specs calls for all aluminum doors. These doors are not made in aluminum, but can be made in Hollow metal. Was it intended for these doors to be Hollow metal? And if so, please provide the appropriate spec sections for quote purposes.

Answer: Doors should be hollow metal as noted on the drawings.

11. Section 15990A subsection 1.6 "TAB SPECIALISTS RESPONSIBILITIES" references section 15995A. Section 15995A was not provided, how are we to factor this into our bid? What is section 15995A?

Answer: Section 15995A is Commissioning of HVAC Systems and due to the small size of the facility is not required for this project. Commissioning of the systems should be accomplished by the testing and balancing and the performance tests required in sections 15990, 15700, and 15700.